



Texas Commission on Environmental Quality

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS: Rescind Boil Water Notice

Public Water System (PWS) name: ZAPATA COUNTY WCID – Hwy 16 EAST

PWS ID: #2530023 Date Boil Water Notice Issued: 06/18/2026

30 TAC 290.46(q) requires a PWS to notify customers that a boil water notice has been rescinded. A public water system shall not rescind a boil water notice until the public water system has met all the applicable requirements as described in 30 TAC 290.46 (q)(6).

Indicate "☒" for all requirements met and **provide documentation** with submittal:

- Sufficient water pressures (>20 psi) are consistently maintained per 30 TAC 290.47 (e).
- Affected area(s) have been thoroughly flushed, and adequate chlorine residual (free >0.2mg/L, chloramine >0.5mg/L) is maintained throughout the system.
- Surface Water Treatment Rule Only - Finished water entering the system has turbidity levels consistently below 1.0 NTU
- Specific actions required by the Executive Director have been met (describe actions):
- Microbiological samples, marked "Special", from representative sites in system, are analyzed by an approved lab, and all results are negative for coliform organisms.

Please indicate how the PWS provided this rescind notification to customers.

COMMUNITY WATER SYSTEM (perform one or more of the following):

- Furnish a copy of the Notice to radio and television stations serving the PWS service area
- Publish Notice in a local newspaper serving the PWS service area
- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

NONCOMMUNITY WATER SYSTEM (perform one or more of the following):

- Direct delivery of Notice to customers
- Continuously post Notice in conspicuous places within affected PWS service area
- Electronic delivery or alert systems (e.g., reverse 911)

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

NOTE: 30 TAC 290.46(q)(6)(F) requires the PWS to provide documentation to the Executive Director within 10 days.

Date of Delivery to Customers: 06/29/26 Phone: (956)765-9650

Certified by: (print name): MIREYA BUSTAMANTE Title: OFFICE MANAGER

Signature: *Mireya Bustamante* Date: 06/29/2026

E-mail (PWSBWN@TCEQ.TEXAS.GOV) or mail a copy of this completed form, AND copies of the Rescind Notice given to your customers to: TCEQ – Water Supply Division MC – 155, Attn: Public Notice. P. O. Box 13087 Austin, TX 78711-3087

Boil Water Rescind Notice

On **June 29, 2026**, the Texas Commission on Environmental Quality (TCEQ) required our public water system **Zapata County Water Control and Improvement District Hwy 16 East**, PWS ID #**2530023** to issue a Boil Water Notice (BWN) to inform our customers that due to the presence of low chlorine residuals, water from our system must be boiled prior to consumption.

Our system has taken the necessary corrective actions to restore adequate pressure, disinfectant levels, and/or bacteriological quality and has provided TCEQ with testing results that indicate that the water no longer requires boiling as of **June 29, 2026**.

If you have questions, contact **Juan F. “Johnny” Delgado at 956-751-8180**.

If a customer wishes to reach TCEQ, they may call 512-239-4691.

TCEQ Microbial Reporting Form (TCEQ-10525)

Form instructions: www.tceq.texas.gov/drinkingwater/microbial/reviseid-total-collform-rule

Water System Identification & Sample Collection Information (Please print or type the information)

Public Water System ID: TX **2530023**

Public Water System Name: **Zapata county WCID Hwy 16**

Name: **Zapata county WCID Hwy 16 E**

Address: **504 State Hwy 16 p.o. Box 427**

City: **Zapata** State: **Texas** Zip Code: **78076**

Phone #: **956 765 9650** PWS Email:



City of Laredo Health Department - Environmental Lab Section
2600 Cedar Ave
Laredo, TX 78040
Phone: (956)-795-4908 Ext. 4693
EL02 Appendix C



TCEQ Laboratory ID: T104704368

Report Results To:

Laboratory Analysis

Sample Iced? Yes No Actual Temp: **12.1** Corrected Temp: **12.3** Lab Comments: **C20260625-2**

Incubation Date and Time: Start Date and Time: **06-25-2026 15:09** Analyst: **MA/MB**
End Date and Time: **06-25-2026 15:09** Analyst: **MA/MB**

Lab Rejected Code (LR) - Document Reason:

Result Reporting and Approval
Laboratory Approval: *[Signature]* Date: **6/26/26** Time: **15:09**
Reported to PWS By: Date: Time:

* SAMPLES MARKED AS SPECIAL OR CONSTRUCTION CANNOT BE USED AS ROUTINE OR REPEAT SAMPLES

| Sample Identification/Location <small>Use sample site location/address identified in the system's RTRC Sample Siting Plan Raw Wells: Use Well Source ID (Ex: G1234567A)</small> | Sample Type (✓ one) | | | | | Collected | | Chlorine Residual | | Original Sample Info: Sample ID and Date of Collection (Repeat, TSM Raw Well, Replacement) | Replacement | Rejection Code (if applicable) - Please Recollect | Test Method: SM9223B-IDEXX | | | | | | Analysis Results meet all accreditation requirements unless stated otherwise. | Laboratory Sample ID Number |
|--|------------------------|--------|----------|---------|--------------|-----------------|---------------------------|-------------------|------------|--|-------------|---|----------------------------|----------------|---|---------|---|--|---|-----------------------------|
| | Routine (Distribution) | Repeat | Raw Well | Special | Construction | Date (MM/DD/YY) | Time Military Time (HHMM) | Free mg/L | Total mg/L | | | | Chlorine Check | Total Coliform | | E. coli | | | | |
| Alberto Trevino | | | | ✓ | | 6-25-26 | 10:50am | 1.7 | | | | | ✓ | | ✓ | | ✓ | | 91533 MA | |
| Minerva Arambola | ✓ | | | | | 6-25-26 | 11:08am | 1.8 | | | | | ✓ | | ✓ | | ✓ | | 91534 | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |

I acknowledge that samples were handled appropriately and all information is accurate. Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37.10)

Sampler Name (Print): **Juan Delgado** Sampler Signature: *[Signature]* Sampler Phone #: **956 751-8180**

Sampler Email:

Relinquished By Sampler: *[Signature]* Date and Time: **6-25-26 12:27** Received By Courier (if applicable):


Relinquished By Courier: *[Signature]* Date and Time: **6-25-26 12:27** Received By Lab: **Margaret Skuniah** Date and Time: **06-25-2026 12:27**

ENV-2026-0820
ZC_WCID_16E_5
Alberto Trevino



91533

ENV-2026-0820
ZC_WCID_16E_5
Milnera Arambula



91534

2026-08-20
16:10:11

2026-08-20
16:10:11

2026-08-20
16:10:11